

Addendum #02

Project:	110 Street UPAR Project - Deep Utilities	Competition Number:	20250211
----------	---	---------------------	-----------------

Date:	February 26, 2025
-------	--------------------------

Distribution:	Public
---------------	---------------

1. GENERAL

- a. The purpose of this Addendum is to answer questions, provide clarification, and make changes to the tender documents to address issues found during the tender process.
- b. Receipt of this addendum shall be acknowledged in the submission of the completed tender.
- c. This addendum shall form part of the contract.
- d. Tenders submitted without this addendum included shall be registered as an invalid tender submission.

2. CHANGES TO TENDER DOCUMENTS

- a. Update **Specification 06600 – Pressure Pipe – Section 2.5 VALVE AND VALVE BOXES - 2.5.1.7 Approved Products** to be:
 - **Meuller A-2360 Resilient Wedge Gate Valve**
 - ~~Clow F-6112 Resilient Wedge Gate Valve~~
 - ~~Bibby Ste-Croix Resilient Wedge Gate Valve~~
 - ~~American AVK Co. Resilient Wedge Gate Valve Series 45 East Jordan Iron Works Flowmaster Resilient Wedge Gate Valve sizes 100 mm to 300 mm diameter~~
 - ~~American Flow Control Series 2500 Resilient Wedge Gate Valves sizes 50mm to 300mm~~
 - **Or equivalent approved by Engineer.**
- b. Update **Specification 06600 – Pressure Pipe – Section 2.6 HYDRANTS - 2.6.11. Approved Products** to be:

- ~~Meuller Modern Centurion~~
- ~~Clow Canada "Brigadier" M-67~~
- ~~East Jordan Watermaster 5CD250~~
- **Canada Valve Century Hydrant with Western Canada Threads**

End of Addendum #02